

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 156/2025-26.

Dated: 29/07/2025

It is certified that an inspection team headed by Mrs. MAMATHA. M.S. (AEE)

(Name of Officers with designation) from BANGALORE WATER SUPPLY & SEWAGE BOARD. PHED

inspected the EDIFY WORLD SCHOOL WHITEFIELD

Sy.No. 54/2, 55/2, KANNAMANGALA, BIDARAHALLI (H), BANGALORE
(Name & Address of the school) on 29/07/25 (date of inspection) and on the basis of -560067

Water Test Report (Attached) bearing no. HATL25020174 dated 29/07/25

of HINDUSTAN ANALYTICAL & TESTING LABORATORY (PHED Lab) certified that

the EDIFY WORLD SCHOOL WHITEFIELD (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 28/07/2026.

Mrs. MAMATHA. M.S.
Assistant Executive Engineer 28/07/25

BWSSB, Mahadevapura Division

Bangalore - 560048

Signature with Seal

Name

Designation

Name & Address of the Office / Department :

To EDIFY WORLD SCHOOL, WHITEFIELD
SY.NO. 54/2, 55/2, KANNAMANGALA
BIDARAHALLI, HOBLI
BANGALORE EAST TALUK

(Name & Address of the Institution)

BANGALORE-560067.

Mrs. MAMATHA. M.S.

ASSISTANT EXECUTIVE
ENGINEER

BWSSB, BANGALORE.

Blore-560048.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 156/2025-26.

Dated: 29/07/2025

It is certified that an inspection team headed by Mrs. MAMATHA. M.S. (AEE)

(Name of Officers with designation) from BANGALORE WATER SUPPLY & SEWAGE BOARD. inspected the EDIFY WORLD SCHOOL WHITEFIELD

Sy. No. 54/2, 55/2, KANNAMANGALA, BIDARAHALLI (H), BANGALORE
(Name & Address of the school) on 29/07/25 (date of inspection) and on the basis of 56006

Water Test Report (Attached) bearing no. HATL25070174 dated 29/07/25

of HINDUSTAN ANALYTICAL & TESTING LABORATORY (PHED Lab) certified that

the EDIFY WORLD SCHOOL WHITEFIELD (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 28/07/2026.

Lumanatha. M.S.
Assistant Executive Engineer

Signature with Seal BWSSB, Mahadevapura Division

Name

Designation

Name & Address of the Office / Department :

EDIFY WORLD SCHOOL WHITEFIELD

To Sy. No. 54/2, 55/2, KANNAMANGALA

BIDARAHALLI HOBLI

BANGALORE EAST TALUK

(Name & Address of the Institution)

BANGALORE-560067.

Mrs. MAMATHA. M.S.

ASSISTANT EXECUTIVE

ENGINEER

BWSSB, BANGALORE.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies BWSSB-560048.

Ranjana
MANAGER

Edify World School Whitefield

Sy No. 54/2, 55/2

Kannamangala,

Bidarahalli Hobli,

Bangalore East Taluk Bangalore - 560067

[Signature]
PRINCIPAL
Edify World School Whitefield

Sy No. 54/2, 55/2

Kannamangala,

Bidarahalli Hobli,

Bangalore East Taluk Bangalore - 560067

HINDUSTAN ANALYTICAL & TESTING LABORATORY

An ISO 9001 : 2015 Certified and NABL Accredited Laboratory

125/6, Ward No 2, Halasina Marada Doddi Road, Bidadi, Ramanagara - 562 109

Mob.: 9844846082, E-mail : info@hatlindia.com, www.infohatlindia.in

TEST REPORT


Page: 1 of 1

Report No: HATL25070174	Report Date : 29/07/2025
Issued to: M/S. The Edify World School Sy. No. 54/2, 55/2, Kannamangala, Bidarahalli Hobli, Bangalore East Taluk, Whitefield, Bangalore - 560067	Customer Reference : Verbal
	Date of Receipt : 25/07/2025
	Date of start of test : 26/07/2025
Sample Collected by: Customer	Date of Completion of test : 29/07/2025
Sample Nature/Name: RO Water	

Description: - Colorless, Odourless, Transparent liquid.

TESTS	RESULTS	Maximum Acceptable Limits (mg/l)	Maximum Permissible Limits (mg/l)	Protocol
		(As per IS 10500:2012)		
Colour, Hazen Units	<5	5	15	IS-3025/Part-4
Odour	Agreeable	Agreeable	Agreeable	IS-3025/Part-5
Turbidity, NTU	<0.1	1	5	IS-3025/Part-10
pH Value	6.55	6.5 – 8.5	No Relaxation	IS-3025/Part-11
Total Hardness as CaCO ₃ , mg/l	52.0	200	600	APHA 23 rd Edition
Calcium as Ca, mg/l	16.0	75	200	APHA 23 rd Edition
Magnesium, as Mg, mg/l	2.9	30	100	APHA 23 rd Edition
Chloride as Cl, mg/l	20.9	250	1000	IS-3025/Part-32
Total Dissolved solids, mg/l	84.0	500	2000	IS-3025/Part-16
Sulphate as SO ₄ , mg/l	2.6	200	400	IS-3025/Part-24
Nitrate as NO ₃ , mg/l	<1.0	45	No Relaxation	IS-3025/Part-34
Fluoride as F, mg/l	<0.1	1.0	1.5	APHA 23 rd Edition
Iron as Fe, mg/l	<0.1	0.3	No Relaxation	IS-3025/Part-53
Chromium as Cr ⁶⁺ , mg/l	<0.05	0.05	No Relaxation	IS-3025/Part-52
Copper as Cu, mg/l	<0.05	0.05	1.5	IS-3025/Part-42
Manganese as Mn, mg/l	<0.1	0.1	0.3	IS-3025/Part-59
Residual Free Chlorine, mg/l	<0.1	0.2	1	IS-3025/Part-26
Total Alkalinity as CaCO ₃ , mg/l	40.0	200	600	IS-3025/Part-23
Aluminium, as Al, mg/l	<0.01	0.03	0.2	IS-3025/Part-55
Boron as B, mg/l	<0.1	0.5	1.0	APHA 23 rd Edition
Microbiological Testing				
Total Coliform /100 ml	Absent	Not Detectable		IS 1622- 1981
E, Coli /100 ml	Absent	Not Detectable		IS 1622- 1981

Remarks: The given water sample meets the maximum acceptable limits as per IS 10500:2012 standard for above physio chemical & microbiological testing. It can be used for drinking purpose



Analyzed by



Authorised Signatory

Note: 1. The results listed pertain only to the tested samples and applicable parameters. 2. Samples will be destroyed after 15 days from the date of issue of Test Certificate unless & otherwise specified. 3. This report is not be reproduced either wholly or in part and can not be used as evidence in the court of law and should not be used in any advertising media without prior written permission. 4. Sampling not done by us, unless specified.

HINDUSTAN ANALYTICAL & TESTING LABORATORY

An ISO 9001 : 2015 Certified and NABL Accredited Laboratory

125/6, Ward No 2, Halasina Marada Doddi Road, Bidadi, Ramanagara - 562 109

Mob.: 9844846082, E-mail: info@hatlindia.com, www.infohatlindia.in

TEST REPORT

Page: 1 of 1

Report No: HATL25070173	Report Date : 29/07/2025
Issued to: M/S. The World School Sy. No. 45/3, Ajjagondanahalli, Anugondanahalli Hobli, Hoskote Taluk, Bangalore - 560087	Customer Reference : Verbal
	Date of Receipt : 25/07/2025
	Date of start of test : 26/07/2025
Sample Collected by: Customer	Date of Completion of test : 29/07/2025

Sample Nature/Name: RO Water

Description: - Colorless, Odourless, Transparent liquid.

TESTS	RESULTS	Maximum Acceptable Limits (mg/l)	Maximum Permissible Limits (mg/l)	Protocol
		(As per IS 10500:2012)		
Colour, Hazen Units	<5	5	15	IS-3025/Part-4
Odour	Agreeable	Agreeable	Agreeable	IS-3025/Part-5
Turbidity, NTU	<0.1	1	5	IS-3025/Part-10
pH Value	7.66	6.5 – 8.5	No Relaxation	IS-3025/Part-11
Total Hardness as CaCO ₃ , mg/l	22.0	200	600	APHA 23 rd Edition
Calcium as Ca, mg/l	5.6	75	200	APHA 23 rd Edition
Magnesium, as Mg, mg/l	1.9	30	100	APHA 23 rd Edition
Chloride as Cl, mg/l	21.9	250	1000	IS-3025/Part-32
Total Dissolved solids, mg/l	65.0	500	2000	IS-3025/Part-16
Sulphate as SO ₄ , mg/l	2.5	200	400	IS-3025/Part-24
Nitrate as NO ₃ , mg/l	1.0	45	No Relaxation	IS-3025/Part-34
Fluoride as F, mg/l	<0.1	1.0	1.5	APHA 23 rd Edition
Iron as Fe, mg/l	<0.1	0.3	No Relaxation	IS-3025/Part-53
Chromium as Cr ⁶⁺ , mg/l	<0.05	0.05	No Relaxation	IS-3025/Part-52
Copper as Cu, mg/l	<0.05	0.05	1.5	IS-3025/Part-42
Manganese as Mn, mg/l	<0.1	0.1	0.3	IS-3025/Part-59
Residual Free Chlorine, mg/l	<0.1	0.2	1	IS-3025/Part-26
Total Alkalinity as CaCO ₃ , mg/l	15.0	200	600	IS-3025/Part-23
Aluminium, as Al, mg/l	<0.01	0.03	0.2	IS-3025/Part-55
Boron as B, mg/l	<0.1	0.5	1.0	APHA 23 rd Edition
Microbiological Testing				
Total Coliform /100 ml	Absent	Not Detectable		IS 1622- 1981
E. Coli /100 ml	Absent	Not Detectable		IS 1622- 1981

Remarks: The given water sample meets the maximum acceptable limits as per IS 10500:2012 standard for above physio chemical & microbiological testing. It can be used for drinking purpose

Analyzed by

Rajesh R
MANAGER
Edify World School Whitefield
Sy No.54/2, 55/2
Kannamangala,

PRINCIPAL
Edify World School Whitefield
Sy No.54/2, 55/2
Kannamangala,
Bidarahalli Hobli



Authorised Signatory

Note: 1. The results listed pertain only to the tested samples and applicable parameters. 2. Samples will be destroyed after 15 days from the date of issue of Test Certificate unless & otherwise specified. 3. This report is not to be reproduced either wholly or in part and can not be used as evidence in the court of law and should not be used in any advertising media without prior written permission. 4. Sampling not done by us, unless specified.